

Addendum #1 for LCPW Job Number: 2026-1

1. Pressure washing inside and outside of can lift stations is an option per PW 6.0 – LCPW Coatings Preparation Specifications 2021-2026. The contractor must protect all electrical components from shorting out or causing damage. This action must be controlled so as not to flood the station or overwhelm the sump pump.
2. If pressure washing, the contractor shall provide water or may rent a water meter from Lake County Public Works. The County has a fire hydrant that can be used to obtain water. There is a fee associated with using our water (meter deposit and gallons used). The amount refunded will be defined upon application request for the County water meter.
3. Paint air valves outside of the can lift station the same color as the lift station (Lake County Green aka Vista Green)
4. Paint ballads near can lift station with safety yellow.
5. The last stair at the bottom of the can lift station shall be painted safety yellow.
6. The contractor may provide their own security lock to be daisy chained to the County's Lock. This will allow the contractor access to each station. If locks are improperly locked up, locks will be cut off for LCPW to have access to the can lift station.
7. Ingleside Shores Lift Station will only have its exterior painted.
8. Manufacture labels, serial numbers, equipment information shall not be painted over. Any data labels shall be protected.

Dimensions:

- All can lift stations are about 4ft wide
- Stanton Point / Bay Lift Station – Deep – Approximately 30ft deep
- Ingleside Shores Lift Station – Exterior Only
- Oak Circle Lift Station – Deep – Approximately 25ft deep
- Jackson Rd Lift Station – Deep – Approximately 30ft deep
- Orchard Dr Lift Station – Shallow – Approximately 15ft deep

Correct Order / Correct Lift Station to be done in 2026:

1. Stanton Point / Bay Lift Station 36932 N Stanton Point Rd. Ingleside Shore, IL 60041
 2. Ingleside Shores Lift Station 26521 Lincoln St. Ingleside, IL 60041
 3. Oak Circle Lift Station 26034 W Oak Cir. Ingleside, IL 60041
 4. Jackson Rd Lift Station 36673 N Jackson Dr. Ingleside, IL 60041
 5. Orchard Dr Lift Station 25540 W Orchard Ave. Ingleside, IL 60041
- (South Cedar Crest Lift Station taken out and Orchard Dr Lift Station put in for this year)