

BID NUMBER # 26285 – Winston Park Storm Sewer Improvements
DATE: 09/22/2026

Addendum 2

1. Bidding/Bidder Question

Q1: Where can we access the project site from?

R1: The project site is located between Skylark Lane and Partridge Lane. The Contractor will be responsible for determining the proposed site access and staging area. The proposed access and staging area shall be reviewed and approved by LCPW and Ciorba Resident Engineering prior to use. One potential staging area is the clubhouse parking lot located at 600 Winston Drive. Use of this area would require additional approval from the HOA.

2. Bidding/Bidder Question

Q2: Could you please confirm we will have access to local hydrants to perform our work?

R2: Yes, LCPW owns the water infrastructure in the vicinity, and the Contractor may utilize the local hydrants for construction activities. The Contractor will be required to complete an application for a water meter rental through LCPW. An RPZ backflow prevention device is required. A deposit will be required for the water meter; however, there is no charge for construction water. The specific hydrant to be used for construction water will be determined at a later date.

END OF ADDENDUM NO. 2