

Lake County Public Works Lift Station Coating Schedule

Exterior Coatings:

Full Prime (one coat to cover): ~~COROTHANE® I MIO-ALUMINUM~~ ,
646 MACRO EPOXY

Finish Coat (one coat to cover): ACROLON® Ultra HP Polyurethane

Interior Coatings:

Prime (one coat to cover): ~~COROTHANE® I MIO-ALUMINUM~~
646 MACRO EPOXY

~~Finish Coat (one coat to cover): EPOLON™ II MULTI-MIL EPOXY~~

Finish Coat (one coat to cover): Dura-Plate 235 MULTI PURPOSE EPOXY /
646 MACRO EPOXY

Floor Leveling: (when specified)

Prime: COROTHANE® I MIO-ALUMINUM

Intermediate Leveler: FasTop 12 S Urethane Slurry System

~~Finish Coat: EPOLON™ II MULTI-MIL EPOXY~~

Finish Coat (one coat to cover): Dura-Plate 235 MULTI PURPOSE EPOXY

COLOR CODE

Lake County Green (Vista Green)

Outside – Exterior & Lid

Interior – Pipes & Pumps

Lemon Mint

Interior – Walls and ceiling

Haze Gray

Interior – Floor & 6” up on wall

Safety Yellow

Interior – Step

Interior – Valve handles

Approved Coatings:

Sherwin-Williams