



Department of Public Works

Austin McFarlane  
Director

650 W. Winchester Road  
Libertyville, Illinois 60048  
Phone 847 377 7500  
Fax 847 984 5665  
[PublicWorks@lakecountyil.gov](mailto:PublicWorks@lakecountyil.gov)

**Lake County Department of Public Works**  
**Saunders Road Sanitary Sewer and Lift Station Improvements**  
**Bid #25232**  
**Project #2020.130**  
**Addendum #5 – September 15, 2025**

Please refer to the “Bid Documents & Technical Specifications and the Bidding Plans” for complete details. Statements, questions and answers below are added for emphasis.

**Questions and Clarifications:**

1. Question: Sheet 50 (350-HEN-3) shows an exhaust fan, 350-EF-1, and intake louvers on the 350 Electrical Enclosure. Sheet 007-E-2 shows provisions for two A/C units (350-AC-1 and 350-AC-2); however, the installation location is not shown on Sheet 50. Please also confirm that both the AC Units and exhaust fans are required. We typically see one or the other.

**Answer:** A/C units are not required. The two A/C units (350-AC-1 and 350-AC-2) shown on Sheet 007-E-2 should be removed, but the exhaust fan will remain (350-EF-1). See revisions in this Addendum.

**Revisions**

**Drawings:**

1. Drawing 007-E-2: Delete this drawing and replace it with the revised version attached to this Addendum.

